

403713

February 28, 2006

The Director  
Environmental Monitoring and Reporting Branch (EMRB)  
135 St. Clair Avenue  
8<sup>th</sup> Floor  
Toronto, ON  
M4V 1P5

Re: Annual Compliance Report, O. Reg. 170/03  
Tobermory Community Centre Water System  
Municipality of Northern Bruce Peninsula  
Reporting Period: January 1, 2005 to December 31, 2005

---

Dear Sir/Madam:

This annual letter report has been prepared to comply with the reporting requirements of O. Reg. 170/03.

### **1.0 DESCRIPTION OF WATER SYSTEM**

The Tobermory Community Centre Water System has been classified as a Small, Municipal, Non-Residential Water System. The water system is located at 7420 Hwy. #6 N, Tobermory, Ontario in the Municipality of Northern Bruce Peninsula.

The water works consists of a 0.95 L/s capacity raw water submersible well pump. The well is located in a garage on the south side of the community centre. The pumping system operates as called for by a pressure switch and there is one (1) pressure tank. Raw water is disinfected by chlorination.

There is no Certificate of Approval (C of A) or Permit to Take Water (PTTW) for this facility.

Part III Form 2 was submitted electronically.

### **2.0 SUMMARY OF SAMPLING RESULTS DURING REPORTING PERIOD**

The results of physical/chemical analyses are attached to this report in the form of the original laboratory report (Caducean Environmental Laboratories). Warning notices have been posted instead of microbiological sampling.

### **3.0 SUMMARY OF ADVERSE TESTING RESULTS AND CORRECTIVE ACTIONS**

There were no adverse results during 2005.

#### **4.0 SUMMARY OF MAJOR EXPENSES INCURRED**

There were no major upgrade expenses incurred to the water system.

Prepared by

OWESON WATER SERVICES  
(a Division of OWESON LTD.)

Geoff Aitken, A. Sc.T.  
Compliance Manager  
GWA/tah  
Encl

cc Ms. Cathy Robins, Administrator, Northern Bruce Peninsula  
Mr. Don Hamilton, MOE Owen Sound Area Office