

403708

February 28, 2006

The Director
Environmental Monitoring and Reporting Branch
135 St. Clair Ave., 8th Floor
Toronto, ON
M4V 1P5

Re: Annual Compliance Report, O. Reg. 170/03
Tobermory Primary Place Daycare Water System
Municipality of Northern Bruce Peninsula
Water Works Identification No. 260024596
Reporting Period January 1, 2005 to December 31, 2005

Dear Sir/Madam:

This annual letter report has been prepared to comply with the reporting requirement of O. Reg. 170/03.

1.0 DESCRIPTION OF WATER SYSTEM

The Tobermory Primary Place Daycare Water System has been classified as a Small Municipal Non-Residential water system. The water system is located in St. Edmunds Township, Part 51-Block 1, 1 East Bury Road, Tobermory, Ontario in the Municipality of Northern Bruce Peninsula. The Daycare is a designated facility and is the only building serviced by the well.

The water works consists of 0.53 L/s capacity raw water submersible well pump.

Raw water passes through a softener then a one (1) micron cartridge filter, before being disinfected by chlorine and ultraviolet light.

There is no Certificate of Approval (C of A) or Permit To Take Water (PTTW) for this facility.

Part III Form 2 was submitted electronically.

2.0 SUMMARY OF SAMPLING RESULTS DURING REPORTING PERIOD

Table 1 summarizes the sampling results during the reporting period for bacteriological parameters. The results of physical/chemical analyses are attached to this report in the form of the original laboratory report (Caducean Environmental Laboratories). The daycare closed at the end of November and as a result the three (3) month sampling program for Nitrite, Nitrate and THMs was not completed. When the daycare reopens in the spring of 2006, the sampling program should include these parameters.

3.0 SUMMARY OF ADVERSE TESTING RESULTS AND CORRECTIVE ACTIONS

There were no adverse results during 2005.

4.0 SUMMARY OF MAJOR EXPENSES INCURRED

There were no major upgrade expenses incurred to the water system.

Prepared by

OWESON WATER SERVICES
(a Division of OWESON LTD.)

Geoff Aitken. A.Sc.T.
Compliance Manager
GWA/tah
Encls.

cc: Ms. Cathy Robins, Administrator, Municipality of Northern Bruce Peninsula
Mr. Don Hamilton, Owen Sound Area Office, MOE

FAX: 793-3823
FAX: 371-2905